



**ISOLATION CABIN 12 ACPH (AIR CHANGE PER HOUR)
WITHOUT AIR LOCK ROOM (20'X8')**

LEGEND

SR. NO.	QUANTITY	ITEMS
D1	01 NOS.	MAIN ENTRANCE DOOR (3'-0" x 6'-6")
C1	02 NOS.	SHADE ABOVE LOUVERS AND WINDOWS
01	01 NOS.	INLINE FAN WITH BIRD NET & VIRUS BURN OUT (VIRUS BURN OUT OPTIONAL)
02	01 NOS.	3 TR DX CONDENSING UNIT
03	01 NOS.	STARTER PANEL
04	01 NOS.	300 CFM 100% FRESH AIR AHU WITH G4,F8 FILTERS,H14 HEPA FILTER, 3 TR COIL & PLUG TYPE FAN
05	01 NOS.	DOOR WITH GRILL (750 X 150)

SR. NO.	QUANTITY	ITEMS
06	01 NOS.	SQ. DIFFUSER (225 X 225)
07	01 NOS.	SS NAHANI TRAP WITH DRAINAGE
08	01 NOS.	BIB TAP WITH ALL PLUMBING
09	01 NOS.	TOILET PAPER HOLDER
10	01 NOS.	EWC WITH ALL PLUMBING, FITTINGS & DRAINAGE
11	01 NOS.	EXTERNAL BULKHEAD LIGHT
12	01 NOS.	WB WITH ALL PLUMBING, FITTINGS & DRAINAGE
13	01 NOS.	SOAP DISH

NOTES

Valisons and Company
68/b, Sarang street, Mumbai 400003
Fone : 022 - 23426251, Fax: 022 - 23447854, E-MAIL : info@valisons.com

SCALE 1:5
UNLESS OTHERWISE STATED :
1. THIRD ANGLE PROJECTION.
2. DO NOT SCALE THE DRAWING.
3. ALL DIMENSION ARE IN mm.
4. GEN. TOLERANCE AS PER IS:2102 (ISO:2768)
5. TOLERANCE FOR FABRICATION OF STEEL STRUCTURES AS PER IS:7215.
COMPUTER DRAFTED
PLOTING SCALE : 1:1
CD NO. :-
FILE NAME :-

TITLE		ISOLATION CABIN 12 ACPH (AIR CHANGE PER HOUR) WITHOUT AIR LOCK ROOM (20'X8')	
DRAWN	SPCS	CHECKED	SHB
APPROVED	ML		
DATE-RO	DATE-CURRENT	DRG.NO. : VC/002/2020	REVISION RO
08.04.2020	08.04.2020		

REV.NO.	R E V I S I O N	DATE	DRN.	CH.	APPD.
RO	FOR MANUFACTURE	08.04.2020	Sonal	SHB	ML